



SMOKE DETECTORS

Section 1210 (a) 1, 2, 3

Smoke Detectors shall be:

- Required in every dwelling unit, congregate residence and in all guest rooms of hotels and lodging houses
- Installed in accordance with the approved manufacturer's instructions
- Installed when sleeping rooms added or repairs or additions requiring permit exceed \$1000.00 valuation
- Hard-wired in new construction and equipped with a battery backup (battery-operated permitted in existing buildings)

Exeter Township
Building Department